



# EXACOR™ SUBFLOORING PRODUCT INSTALLATION CHECKLIST

General Contractor/Installer	Project Name	Project Location
Observer's Name	Jobsite Superintendent	Date of Observation

## EXACOR™ PRODUCT INSTALLATION CHECKLIST:

#	Item	YES	NO	N/A	Other*
<b>EXACOR™ Subflooring</b>					
1	Is framing flat and level prior to subflooring installation?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Is smooth side facing up?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Are panels installed tight on all edges?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3a	What edge profile was used? <input type="checkbox"/> Shiplap <input type="checkbox"/> Tongue & Groove (T&G)				
3b	If not T&G, Are all panel edges supported with framing or blocking?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Are fasteners used powder coated, stainless steel, yellow zinc coated or hot-dipped galvanized?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	What fasteners are used?	Size & Length:			
6	Is edge fastener spacing: 6" maximum?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Is field fastener spacing: 12" maximum?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Are fasteners 1/2" minimum from panel edges?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Are fasteners 2" minimum from panel corners?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Are high traffic areas or areas with high point loads covered with protective OSB or plywood panels during construction?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	What framing type is used? (Open-web truss, I-joist, Solid Sawn, Lt. Ga. Metal)				
12	What on-center spacing is floor framing?				
13	Was subfloor adhesive used?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Notes: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Additional Notes: \_\_\_\_\_

\_\_\_\_\_

This observation report is being provided at your request and for your benefit and at no cost to you. This report is intended to be used only by you and is intended for general information purposes only; it is not a substitute for specific professional advice. In preparing this report, Huber Engineered Woods LLC (HEW) used reasonable efforts to provide information relating to the installation of EXACOR™ products at the project site identified above. HEW DOES NOT WARRANT OR GUARANTEE THE ACCURACY, COMPLETENESS, OR ADEQUACY OF THE INFORMATION CONTAINED IN THE REPORT REGARDING YOUR PROJECT, AND HEW HEREBY SPECIFICALLY DISCLAIMS ANY LIABILITY FOR THE CONTENT OF THIS OBSERVATION REPORT AND FOR THE CONSEQUENCES OF ANY ACTIONS TAKEN ON THE BASIS OF THE INFORMATION PROVIDED. The observation was done and the report created during the construction process and as such, not all aspects of the installation may have been accessible, viewable or complete. Work executed after the completion of these forms may affect the installation as observed. Any reference to or mentioning of any other commercial product, process, or service (or provider of such product, process or service) by trade name, trademark, hyperlink, or otherwise, does not constitute or imply an endorsement or recommendation by Huber Engineered Woods LLC and is for informational purposes only. © 2017 Huber Engineered Woods LLC. EXACOR, the EXACOR logo and the accompanying design are trademarks of Huber Engineered Woods LLC. Huber is a trademark of J.M. Huber Corporation. HUB 82391 REV 1/21

\*If checked other, please explain in additional notes. List the number of the item you are providing an explanation for.